Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PH03/HI/2026 Dated: 06.06.2026

It is certified that an inspection team headed by JOB. G

Health Inspector (Name of Officers with designation)

from PHC Thakazhy, Alappuzha, Kerala PHED

inspected the Carmel English Medium school, Thakazhy, Alappuzha

(Name & Address of the school) on 11/05/2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 757/A/2026

dated 31.03.2026 Kerala Water Authority (PHED Lab), Alappuzha Lab

certified that the Carmel English Medium school,

Thakazhy, Alappuzha, (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 30.03.2027

Signature with Seal .....

Name : JOB. G

Designation Health Inspector

Name & Address of the Office / Department .....

To

.....

.....

(Name & Address of the Institution)

PRIMARY HEALTH CENTRE
Date .....
THAKAZHY - 688 562

ഹെൽത്ത് ഇൻസ്പെക്ടർ
പ്രാഥമിക ആരോഗ്യകേന്ദ്രം തകഴി
തകഴി പി.ഒ., ആലപ്പുഴ
പിൻ - 688 562

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

QUALITY CONTROL SUB DISTRICT LAB

KERALA WATER AUTHORITY

AMBALAPPUZHA, VAZHICHERY, ALAPPUZHA

(NABL Recognized Block Level Government Drinking Water Testing Laboratory)

Telephone No. 0477-2966650 Email :aeqcsdlambpzha@gmail.com

Certificate NO: NABL – DWT - 00942 **WATER ANALYSIS REPORT**

Report No: 757/A/2026	Date: 31/03/2026

Customer Name & Address		
Carmel E M School Thakazhy Kuttanadu P O Alappuzha	1.Date of Receipt	: 26/03/2026
	2.Sampling done by	: Customer
	3.Sample Code	: 2026/QCSDL/AMB/A 757
	4.Source of Sample	: Tap Water (Filter)
	5.Sample Quantity	: 2 Lr
	6.Test performing dates From: 26/03/2026 To: 31/03/2026	

Sl. No	Characteristics	Unit	Desirable limits As per IS 10500:2012	Test Method	Result
1	Turbidity	(NTU)	1	IS 3025(part10)-1984 (Reaffirmed 2023)	0.87
2	pH at --25--- ^{0}C	-	6.5-8.5	IS 3025(part 11)-1983 (Reaffirmed 2022)	7.12
3	Total Hardness (as $CaCO_3$)	(mg/litre)	200	IS 3025(part21)-2009 (Reaffirmed 2019)	38.0
4	Chloride(as Cl)	(mg/litre)	250	IS 3025(part32)-1988 (Reaffirmed 2019)	23.14

QUALITY CONTROL SUB DISTRICT LAB * KERALA WATER AUTHORITY * AMBALAPPUZHA ALAPPUZHA PIN-688 001

Verified & Authorized By

Chemist
Shyna Pushpadas

NB: The result stated above related only to the sample(s) submitted for testing. The test Certificate shall not be produced except infull without the written approval of the Laboratory.

Sample will be retained only for7 days after completion of analysis
Sampling is not done by the Lab

End of the Report

QUALITY CONTROL SUB DISTRICT LAB

KERALA WATER AUTHORITY

AMBALAPPUZHA, VAZHICHERY, ALAPPUZHA

Telephone No. 0477-2966650

Email :aeqcsdlambpzha@gmail.com

WATER ANALYSIS REPORT

Report No: 757/A/2026	Date: 31/03/2026

Customer Name & Address		
Carmel E M School Thakazhy Kuttanadu P O Alappuzha	1.Date of Receipt	: 26/03/2026
	2.Sampling done by	: Customer
	3.Sample Code	: 2026/QCSDL/AMB/A 757
	4.Source of Sample	: Tap Water (Filter)
	5.Sample Quantity	: 2 Lr
	6.Test performing dates From: 26/03/2026	To: 31/03/2026

Sl. No	Characteristics	Unit	Desirable limits As per IS 10500:2012	Test Method	Result
1	Electrical conductivity at …25… ^{0}C	(micro mhos/cm)	-	IS 3025(part14)-2013 (Reaffirmed 2019)	128.7
2	Iron (as Fe)	(mg/litre)	1	IS 3025(part53)-2003 (Reaffirmed 2014)	0.10
3	Nitrate (as NO_3)	(mg/litre)	45	Kit Method	30

Verified & Authorized By

Chemist
Shyna Pushpadas

QUALITY CONTROL SUB DISTRICT LAB * KERALA WATER AUTHORITY * AMBALAPPUZHA ALAPPUZHA PIN-688 001

NB: The result stated above related only to the sample(s) submitted for testing. The test Certificate shall not be produced except infull without the written approval of the Laboratory.

Sample will be retained only for7 days after completion of analysis
Sampling is not done by the Lab
BDL-Below Detection Limit

QUALITY CONTROL SUB DISTRICT LAB

KERALA WATER AUTHORITY

AMBALAPPUZHA, VAZHICHERY, ALAPPUZHA

Telephone No. 0477-2966650

Email : aeqcsdlambpzha@gmail.com

Report No: 757/A/2026	Date: 31/03/2026

Customer Name & Address		
Carmel E M School **Thakazhy** **Kuttanadu P O** **Alappuzha**	1.Date of Receipt	: 26/03/2026
	2.Sampling done by	: Customer
	3.Sample Code	: 2026/QCSDL/AMB/A 757
	4.Source of Sample	: Tap Water (Filter)
	5.Sample Quantity	: 250 ml
	6.Test performing dates From: 26/03/2026 To: 31/03/2026	

BACTERIOLOGICAL ANALYSIS

Sl. No	Parameters	Acceptable limits as per – IS 10500 – 2012	Test Method	Result
1	Coliforms	Shall not be detected/100 ml	IS15185:2016	**ABSENT**
2	E-coli	Shall not be detected/100 ml	IS15185:2016	**ABSENT**

Remarks:-

NB:-The results stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

Test Method:
Coliform - Membrane Filtration Method
E- Coli- Membrane Filtration Method

QUALITY CONTROL SUB DISTRICT LAB * AMBALAPPUZHA ALAPPUZHA PIN-688 001 * KERALA WATER AUTHORITY *

Authorized by

End of the report

കേരള സംസ്ഥാന ആരോഗ്യവകുപ്പ്

നമ്പർ 48 തീയതി : 06/06/2024

സാനിട്ടറി സർട്ടിഫിക്കറ്റ്

PH03/HI/2024

തകഴി കുടുംബാരോഗ്യകേന്ദ്രം, തകഴി.

(1) LSGD- Circular No. 66562/RC3/12/1SD/Dt./10.012023
(2) Service Act No. O-M-3/30892/12 DHS/Dt./6-6.2104
(3) No. 1623/A-R(12)2/2013 ഉ.ഭ.പ.വ. tvm/Dt./8-4-2014

ആലപ്പുഴ ജില്ലയിൽ തകഴി ഗ്രാമപഞ്ചായത്തിൽ ..തകഴി.. പ്രദേശത്ത് 7/212 -ാം നമ്പർ കെട്ടിടത്തിൽ പ്രവർത്തിച്ചുവരുന്ന ..മാർക്ക് ഇന്റിക്ക് ബിരിയാണി സ്റ്റാൾ, തകഴി.. എന്ന സ്ഥാപനത്തിൽ ..11/5/2024..തീയതിയിൽ ഈ സ്ഥാപനത്തിലെ ഹെൽത്ത് ഇൻസ്പെക്ടർ പരിശോധിച്ചു. ടി യൂണിറ്റ് ..—.. കുതിരശക്തിയിൽ പ്രവർത്തിക്കുന്ന ..—.. സർവ്വേ നമ്പർ(മുനിസിപ്പാലിറ്റി), ..കാവുങ്കൽ.. എന്നയാളുടെ ഉടമസ്ഥതയിലുമാണ്.

യൂണിറ്റും പരിസരവും പരിശോധിച്ചപ്പോൾ സാനിട്ടറി കണ്ടീഷൻസ് തൃപ്തികരമെന്നു ബോദ്ധ്യമായി. ..തകഴി.. പഞ്ചായത്തിൽനിന്നും ലൈസൻസിനുവേണ്ടി താഴെപ്പറയുന്ന വ്യവസ്ഥകൾക്കും നിബന്ധനകൾക്കും വിധേയമായി സ്ഥാപനത്തിന് സാനിട്ടറി സർട്ടിഫിക്കറ്റ് അനുവദിക്കുന്നു.

1. പൊതുജനാരോഗ്യശല്യമുണ്ടാകാത്ത രീതിയിൽ സ്ഥാപനം പ്രവർത്തിക്കണം.
2. മാലിന്യം പൊതുജനാരോഗ്യത്തിന് ഹാനികരമാകാത്തവിധത്തിൽ ശാസ്ത്രീയമായി നീക്കം ചെയ്യണം.
3. ജലസ്രോതസ്സും മറ്റും സാംക്രമികരോഗങ്ങൾ ഉണ്ടാകാത്തവിധത്തിൽ സംരക്ഷിക്കണം.
4. ഈ സ്ഥാപനത്തിൽനിന്നും ജലം, വായു മലിനീകരണം ഉണ്ടാക്കുന്ന പ്രവർത്തനം പാടില്ല.
5. സ്ഥാപനവും പരിസരവും സാംക്രമികരോഗങ്ങൾ ഉണ്ടാകാത്ത രീതിയിൽ സംരക്ഷിക്കണം.
6. ജീവനക്കാർ സാംക്രമികരോഗങ്ങളിൽനിന്നും മുക്തരായിരിക്കേണ്ടതാണ്.
7. പുകയിലമുക്തം സൈൻബോർഡ് പ്രദർശിപ്പിച്ചിരിക്കേണ്ടതും സ്ഥാപനം പുകവലിമുക്തമെന്ന് ഉറപ്പുവരുത്തേണ്ടതുമാണ്.
8. അന്യസംസ്ഥാനതൊഴിലാളികൾ സ്ഥാപനത്തിലുണ്ടെങ്കിൽ അടുത്തുള്ള പ്രാഥമികാരോഗ്യകേന്ദ്രത്തിലെ മെഡിക്കൽ ആഫീസറെ അറിയിക്കേണ്ടതാണ്.
9. പ്ലാസ്റ്റിക് മാലിന്യം പരിസരത്ത് കത്തിക്കുകയോ വലിച്ചെറിയുകയോ ചെയ്യരുത്. പ്ലാസ്റ്റിക് മാലിന്യം ശേഖരിച്ച് ശാസ്ത്രീയമായി സംസ്കരിക്കണം.
10. പൊതുജനാരോഗ്യനിയമവും പഞ്ചായത്ത് രാജ് നിയമവും ചട്ടങ്ങളും മറ്റു ബന്ധപ്പെട്ട നിയമങ്ങളും മറ്റ് നടപടിക്രമങ്ങളും പാലിച്ചിരിക്കണം.
11. ഭാവിയിൽ ഏതെങ്കിലും തരത്തിലുള്ള വികസനപ്രവർത്തനങ്ങൾ ഈ ഓഫീസിൽനിന്നും ലഭിക്കുന്ന അനുമതിക്ക് വിധേയമായിരിക്കണം.
12. മുകളിൽ പറഞ്ഞ നിബന്ധനകളിൽ ഏതെങ്കിലും പാലിക്കാതെ വന്നാൽ മറ്റൊരു അറിയിപ്പും കൂടാതെ സാനിട്ടറി സർട്ടിഫിക്കറ്റ് റദ്ദു ചെയ്യുന്നതാണ്.
13. സാനിട്ടറി സർട്ടിഫിക്കറ്റ് ഉണ്ടെങ്കിലും പഞ്ചായത്ത് ലൈസൻസ് ലഭ്യമാകുന്ന മുറയ്ക്ക് പ്രവർത്തനാനുമതി ഉണ്ടാവുകയുള്ളൂ.

PRIMARY HEALTH CENTRE Date 06/6/2024 THAKAZHY -PIN 562

ഹെൽത്ത് ഇൻസ്പെക്ടർ
കുടുംബാരോഗ്യകേന്ദ്രം, തകഴി

ഹെൽത്ത് ഇൻസ്പെക്ടർ
കുടുംബാരോഗ്യകേന്ദ്രം തകഴി
തകഴി പി.ഒ., ആലപ്പുഴ
പിൻ - 688 562